ATTESTATION OF CONFORMITY

Issued to:	Super B Lithium Power B.V. Demmersweg 3 7556 BN Hengelo (OV) The Netherlands	
For the product:	Rechargeable lithium battery	
Trade name:	Super B	
Type/Model:	SB12V210E-ZC and SB12V180E-ZC	
Ratings:	SB12V210E-ZC: Nominal voltage 12,8 Vdc; 210 Ah, 2688 Wh SB12V180E-ZC: Nominal voltage 12,8 Vdc; 180 Ah, 2304 Wh	
Manufactured by:	Super B Lithium Power B.V. Demmersweg 3 7556 BN Hengelo (<i>QV</i>) The Netherlands	
Subject:	Compliance of rechargeable lithium batteries with the below mentioned standard	
Requirements: UN Recommendations on the Transport of Dangerous Goods:2015-Sec 2017		
This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a		

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no 2235632.60.

The examination has been carried out on/one single/specimen/or/several specimens/of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 27 June 2019

Number: 2235632.01-AOC

DEKRA Certification B.V.

H.R.M. Barends Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

DEKRA Certification B.V. Meander 1051, 6825 MJ Arnhem P.O. Box 5185, 6802 ED Arnhem, The Netherlands T +31 88 96 83000 F +31 88 96 83100 www.dekra-certification.com Company registration 09085396

ANNEX TO ATTESTATION OF CONFORMITY

Number: 2235632.01

The following test program has been performed according UN recommendations on the transport of dangerous goods, section 38.3 (6th revised edition + Amendment 1, 2017)

Test	Name	Performed/Not applicable
T.1	Altitude simulation	Performed
T.2	Thermal test	Performed
T.3	Vibration	Performed
T.4	Shock	Performed
T.5	External short circuit	Performed
Т.6	Impact / Crush	Not applicable
T.7*	Overcharge	Not applicable
T.8	Forced discharge	Not applicable

*) The batteries not equipped with battery overcharge protection that are designed for use only as a component in another battery or in equipment, which affords such protection are not subject to the requirement to the overcharge test.

DEKRA Certification B.V.

 $\ensuremath{\mathbb{C}}$ Integral publication of this attestation and adjoining reports is allowed